



Las Vegas Fire & Rescue Fire Prevention Division Information Sheet



Effective Date: February 1, 2011

CLV Ordinance #6124

The items listed are basic information only. Codes are subject to change. Additional requirements may apply.

FIRE SAFETY SURVEY CHILD CARE FACILITY

Business Name: _____ Date: _____
 Address: _____
 City _____ State _____ Zip Code _____
 Person Contacted: _____ Inspector: _____ Hours of Operation: _____

- Approved plans required for construction/remodel.
- Install smoke detectors in all sleeping/napping areas.
- Bathroom and closet doors must open from the inside and outside.
- Provide 2-A:10-B:C fire extinguisher.
- Mount fire extinguisher with top no higher than 5 feet from floor.
- Service and tag fire extinguisher by a Nevada State Licensee.
- Provide adequate protection for heaters, fireplaces and other similar devices.
- Discontinue use of portable heaters and/or unvented wall heaters.
- All heating equipment and water heaters must be enclosed to avoid contact.
- Install Fire Sprinkler System. (Child care between 12 a.m. & 6 a.m.)
- Provide non-combustible waste containers with tight fitting lid.
- Provide 2 unobstructed exits, one which leads directly outside.
- Install emergency lighting with battery back-up.
- Exit doors must be at least 3 feet in width.
- Security bars, gates or other barriers on doors/windows shall be openable from the inside.
- Post evacuation plan.
- Provide record of monthly fire drills.
- Provide child-resistant covers on electrical outlets.
- Reduce storage of flammable liquids to 10 gallons or less.
- Discontinue use of extension cords.
- Gas water heater must be 18 inches above floor.
- Post address on building.

- NAC 477.562**
- NAC 477.562**
- NAC 477.562**
- NAC 477.562**
- NFPA 10**
- NAC 477.410**
- NAC 477.562**
- NAC 477.562**
- NAC 477.562**
- NAC 477.562**
- NAC 477.562**
- NFPA101:16.2.4**
- NFPA 101: 7.8.1.2**
- NFPA 101**
- IFC 1030.7**
- NFPA 101:4.8**
- NFPA 101:4.7**
- NAC 477.562**
- NAC 477.562**
- IFC 605.5**
- NFPA 54**
- CLV Ord. #3744**



**Las Vegas Fire & Rescue
Fire Prevention Division
Information Sheet**



Comments: _____

A reinspection will be conducted in _____ days.

Las Vegas Fire & Rescue
Fire Prevention Division
(702)229-0366
www.lasvegasnevada.gov/LawsCodes/fire_code.asp